



Red River Authority of Texas

JERRY BOB DANIEL, President, Truscott
CONRAD J. MASTERSON, JR. Vice President, Cee Vee
MARY LOU BRADLEY, Secretary/Treasurer, Memphis
TONYA D. DETTEN, Assistant Secretary, Panhandle
JERRY DAN DAVIS, Wellington
MICHAEL R. SANDEFUR, Texarkana
STEPHEN A. THORNHILL, Denison
JOE L. WARD, Telephone
VACANCY

FABIAN A. HEANEY, General Manager
BRYAN D. SCHAFFNER, Assistant General Manager
Crystal Santos, Controller
CARA A. GLASSCOCK, Administration Manager

July 11, 2025

NOTICE OF DRINKING WATER

Maximum Contaminant Level Violation, MCL, LRAA/Total Haloacetic Acids (HAA5)

RRA – Foard County Water System, ID No. 0780014

Second Quarter 2025

The Texas Commission on Environmental Quality (TCEQ) has notified the **RRA Foard County Public Water System TX0780014** that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for haloacetic acids (group of five). The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for haloacetic acids (group of five) to be 0.060 milligrams per liter (mg/L) based on a locational running annual average (LRAA), and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for haloacetic acids (group of five) indicates a compliance value in **quarter two** of **0.076** mg/L for location **DBP2-01**.

Haloacetic acids are a group of volatile organic compounds that are formed when chlorine, added to the water during the treatment process for disinfection, reacts with naturally-occurring organic matter in the water.

Some people who drink water containing HAA5 in excess of the MCL over many years may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

HAA5 is already present in the water when purchased from Greenbelt Municipal and Industrial Water Authority. The Authority is addressing the issue by working with Greenbelt Municipal and Industrial Water Authority to correct the violation that has occurred. The Authority will send letters until the running annual average is below the required MCL.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For further information, please contact our Main Office at (940) 723-8697. You may also contact the Assistant General Manager, Mr. Bryan Schaffner, at (940) 723-8697.

Sincerely,

RED RIVER AUTHORITY OF TEXAS

Jared York
Administrative Assistant

Posted /Delivered on: 07-11-2025