

## Red River Authority of Texas

JERRY BOB DANIEL, President, Truscott
CONRAD J. MASTERSON, JR. Vice President, Cee Vee
TONYA D. DETTEN, Assistant Secretary, Panhandle
JERRY DAN DAVIS, Director, Wellington
JOE L. WARD, Director, Telephone
MICHAEL R. SANDEFUR, Director, Texarkana
VACANCY, Director, Region 1
VACANCY, Director, Region 2

FABIAN A. HEANEY, General Manager BRYAN D. SCHAFFNER, Assistant General Manage CRYSTAL SANTOS, Controller CARA A. GLASSCOCK. Administration Manager

## June 10, 2025 NOTICE OF DRINKING WATER TOTAL TRIHALOMETHANES AND HAA5 VIOLATION RRA – Farmers Valley Water System, ID No. 2440007 Third Quarter 2025

The Texas Commission on Environmental Quality (TCEQ) has notified the **RRA Farmers Valley Public Water System TX2440007** that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for total trihalomethanes (TTHM). The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for total trihalomethanes to be 0.080 milligrams per liter (mg/L) based on a locational running annual average (LRAA) and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for total **trihalomethanes** indicates a compliance value in **quarter three** of **0.198 mg/L** for **DBP2-01**.

Trihalomethanes are a group of volatile organic compounds that are formed when chlorine, added to the water during the treatment process for disinfection, reacts with naturally-occurring organic matter in the water.

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidney, or central nervous systems, and may have an increased risk of getting cancer.

The Texas Commission on Environmental Quality (TCEQ) has notified the **RRA FARMERS VALLEY WATER SYSTEM PWS 2440007** public water system that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for total haloacetic acids. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for total haloacetic acids to be 0.060 milligrams per liter (mg/L) based on a locational running annual average (LRAA) and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for total **haloacetic acids** indicates a compliance value for **quarter three** of **0.114 mg/L** for **DBP2-01**.

Haloacetic acids are a group of volatile organic compounds that are formed when chlorine, added to the water during the treatment process for disinfection, reacts with naturally-occurring organic matter in the water.

Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want totalk to your doctor to get more information about how this may affect you.

TTHM and HAA5 ar already present in the water when purchased from Greenbelt Municipal and Industrial Water Authority. The Authority is addressing the issue by working with Greenbelt Municipal and Industrial Water Authority to correct the violation that has occurred. The Authority will send letters until the running annual average is below the required MCL.

P.O. Box 240 · Wichita Falls, Texas 76307-0240 **Telephone:** (940) 723-8697 **E-Mail:** info@rra.texas.gov **Solution:** 3000 Hammon Road · Wichita Falls, Texas 76310-7500 **Fax:** (940) 723-8531



## Red River Authority of Texas

JERRY BOB DANIEL, President, Truscott
CONRAD J. MASTERSON, JR. Vice President, Cee Vee
TONYA D. DETTEN, Assistant Secretary, Panhandle
JERRY DAN DAVIS, Director, Wellington
JOE L. WARD, Director, Telephone
MICHAEL R. SANDEFUR, Director, Texarkana
VACANCY, Director, Region 1
VACANCY, Director, Region 2
VACANCY, Director, Region 3

FABIAN A. HEANEY, General Manager BRYAN D. SCHAFFNER, Assistant General Manager CRYSTAL SANTOS, Controller CARA A. GLASSCOCK, Administration Manager

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For further information, please contact our Main Office at (940) 723-8697. You may also contact the Assistant General Manager, Mr. Bryan Schaffner, at (940) 723-8697. Sincerely,

## RED RIVER AUTHORITY OF TEXAS

Administrative Assistant

Posted /Delivered on: 09-11-2025

**Telephone:** (940) 723-8697 E-Mail: info@rra.texas.gov Fax: (940) 723-8531