



Red River Authority of Texas

JERRY BOB DANIEL, President, Truscott
CONRAD J. MASTERSON, JR. Vice President, Cee Vee
TONYA D. DETTEN, Treasurer/Secretary, Panhandle
JERRY DAN DAVIS, Assistant Secretary, Wellington
JOE L. WARD, Director, Telephone
MICHAEL R. SANDEFUR, Director, Texarkana
RUBEN ARIAS, Director, Amarillo
RON MULLINS, Director, Archer City
TROY WEBER, Director, Denison

FABIAN A. HEANEY, General Manager
BRYAN D. SCHAFFNER, Assistant General Manager
CARA A. GLASSCOCK, Administration Manager
RYLAN L. JOHNSON, Controller

April 23, 2026

**Mandatory Language for a Maximum Residual Disinfectant Level (MRDL) Violation
MRDL (CHLORINE/CHLORAMINE)
RRA – Farmers Valley Water System, ID No. 2440007**

The Texas Commission on Environmental Quality (TCEQ) has notified **RRA FARMERS VALLEY WATER SYSTEM: TX2440007** that the drinking water being supplied to customers has exceeded the Maximum Residual Disinfectant Level (MRDL) for chlorine. The U.S. Environmental Protection Agency (U.S. EPA) has established the MRDL for chlorine to be 4.0 mg/L based on a running 12-month annual average and has determined that it is a health concern at levels above the MRDL.

Those who consume water containing chlorine in excess of the MRDL could experience irritating effects to their eyes and nose or stomach discomfort. During FOURTH QUARTER 2025 chlorine residual levels exceeded the running 12-month annual average of 4.0 mg/L.

The following actions are being taken to address this issue:

The Authority receives wholesale water already chlorinated through Greenbelt Municipal & Industrial Water Authority (GMIWA). The Authority does not provide secondary chlorine treatment. We will contact GMIWA to see if they are having operational or equipment issues, and attempt to get them to lower the chlorine dosage so we can come back into compliance. For operational information, please contact your District Operator, Mr. Trance Alston at 940-636-8037, or Mr. Barry Hines, Regional Manager at 940-432-8595.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions concerning this matter, you may contact Bryan Schaffner, Assistant General Manager, at 940-723-8697. Additional information may be found at the Red River Authority of Texas website at www.tra.texas.gov.

Sincerely,

RED RIVER AUTHORITY OF TEXAS

A handwritten signature in blue ink that reads "Jared York".

Jared York
Administrative Assistant

Posted /Delivered on: 04-23-2026